

Domestic Fire Sprinkler Information for New Appointments and Variations (NAVs)

dwrcymru.com

Table of Contents

Domestic Fire Sprinkler Information for NAVs	3
1. Introduction	
2. Fire Sprinkler System Design	3
3. Water Supply Pressure/Flow	
4. Further Information	

Version Control

Version Number	Date of Issue	Modifications to previous issue
Vs2.0.	15 March 2021	Update to general text of the introduction and the contact address for The Residential Sprinkler Association
Vs3.0	18 th February 2022	Minor revision of text and addition of sentence below

Domestic Fire Sprinkler Information for NAVs

1. Introduction

In February 2011, the Welsh Government implemented the Domestic Fire Safety (Wales) Measure 2011 which phased in the mandatory installation of fire suppression systems into new or converted properties. Since April 2014, the regulation has applied to high-risk properties such as care homes, new and converted student halls of residence, boarding houses and certain hostels, and since January 2016, to all new and converted houses and flats.

2. Fire Sprinkler System Design

The fire sprinkler system must be designed, installed, and tested in accordance with BS 9251:2014 (Fire Sprinkler Systems for Domestic and Residential Occupancies - Code of Practice) or BS 8458:2015 (Fixed Fire Protection Systems – Residential and Domestic Water Mist Systems – Code of Practice for Design and Installation).

Please note that Dŵr Cymru Welsh Water (Dŵr Cymru) does not design domestic fire sprinkler systems, assess the efficiency, appropriateness or compliance of a fire sprinkler system in relation to any Building Control Regulations, British Standards or Codes of Practice.

3. Water Supply Pressure/Flow

Dŵr Cymru cannot guarantee a water supply or a particular pressures or flow in the water supply distribution system due to a range of circumstances which are beyond our control (for example, low or temporarily reduced pressure/flow may be caused by high customer demand, bursts or leaking mains/services and private supply pipes).

Properties in Dŵr Cymru's area have a minimum operational pressure of 1.5 bar. Water supply networks are subject to fluctuating operational pressure and Dŵr Cymru will not commit to providing a NAV a specified pressure to the site.

4. Further Information

Further information on domestic / residential fire sprinkler systems can be obtained from:

BAFSA (British Automatic Fire Sprinkler	The Residential Sprinkler Association
Association)	Park Court
Richmond House	Brimpton
Broad Street	RG7 4ST
Ely	Tel 0118 971 2322
CB7 4AH	Email info@firesprinklers.org.uk
Tel 01353 659187	Web www.firesprinklers.org.uk
Email info@bafsa.org.uk	
Web <u>www.bafsa.org.uk</u>	